



Takoma RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005397	5/21/2020	5/21/2021	Basement	Cooler	In women's locker room	Low	Right	WF-05212020-005397	3/9/2021	FT-FY21-022021-005397-A	<1	FT-FY21-022021-005397-B	<1
WS- 005398	5/21/2020	5/21/2021	Basement	Cooler	In women's locker room	High	Left	WF-05212020-005398	3/9/2021	FT-FY21-022021-005398-A	<1	FT-FY21-022021-005398-B	<1
WS- 005399	5/21/2020	5/21/2021	Basement	Cooler	in mens locker room	High	Left	WF-05212020-005399	3/9/2021	FT-FY21-022021-005399-A	<1	FT-FY21-022021-005399-B	<1
WS- 005400	5/21/2020	5/21/2021	Basement	Cooler	in mens locker room	Low	Right	WF-05212020-005400	3/9/2021	FT-FY21-022021-005400-A	<1	FT-FY21-022021-005400-B	<1
WS- 005401	5/21/2020	5/21/2021	1	Cooler	In hallway adjacent to the kitchen	Low	Right	WF-05212020-005401	3/9/2021	FT-FY21-022021-005401-A	<1	FT-FY21-022021-005401-B	<1
WS- 005402	5/21/2020	5/21/2021	1	Cooler	In hallway adjacent to the kitchen	High	Left	WF-05212020-005402	3/9/2021	FT-FY21-022021-005402-A	<1	FT-FY21-022021-005402-B	<1
WS- 005413	5/21/2020	5/21/2021	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Street adjacent to playground	High	Left	WF-05212020-005413	3/9/2021	FT-FY21-022021-005413-A	<1	FT-FY21-022021-005413-B	<1
WS- 005414	5/21/2020	5/21/2021	Ground Floor	Cooler	In hallway in accessory building north of Van Buren Street adjacent to playground	Low	Right	WF-05212020-005414	3/9/2021	FT-FY21-022021-005414-A	<1	FT-FY21-022021-005414-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 005403	1/27/2021	1/27/2022	1	Food Prep Sink	In Aquatic Ctr 104 concession stand	WF-01272021-005403	3/9/2021	FT-FY21-022021-005403-A	<1	FT-FY21-022021-005403-B	<1	
WS- 005405	1/22/2020	1/22/2021	Ground Floor	Food Prep Sink	In kitchen 157	WF-01222020-005405	3/9/2021	FT-FY21-022021-005405-A	<1	FT-FY21-022021-005405-B	<1	
WS- 005412	1/29/2020	1/29/2021	Ground Floor	Food Prep Sink	In kitchen in accessory building north of Van Buren Street adjacent to playground	WF-01292020-005412	3/9/2021	FT-FY21-022021-005412-A	<1	FT-FY21-022021-005412-B	<1	